DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES Office of Structural Materials

Quality Assurance and Source Inspection

Bay Area Branch 690 Walnut Ave.St. 150 Vallejo, CA 94592-1133 (707) 649-5453 (707) 649-5493



Contract #: 04-0120F4

Cty: <u>SF/ALA</u> Rte: <u>80</u> PM: <u>13.2/13.9</u>

File #: 69.28

WELDING INSPECTION REPORT

Resident Engineer:Siegenthaler, Peter **Report No:** WIR-023973 **Address:** 333 Burma Road **Date Inspected:** 16-May-2011

City: Oakland, CA 94607

Project Name: SAS Superstructure OSM Arrival Time: 700
Prime Contractor: American Bridge/Fluor Enterprises, a JV OSM Departure Time: 1900

Contractor: Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island Location: Shanghai, China

CWI Name: CWI Present: Yes Li Yang No **Inspected CWI report:** Yes N/A **Rod Oven in Use:** Yes No No N/A N/A **Electrode to specification:** Yes No **Weld Procedures Followed:** Yes No N/A N/A **Qualified Welders:** Yes No **Verified Joint Fit-up:** Yes No N/A N/A Yes N/A **Approved Drawings:** Yes No **Approved WPS:** No Yes No N/A **Delayed / Cancelled:**

Bridge No: 34-0006 Component: Orthotropic Box Girder (OBG)

Summary of Items Observed:

On this date Caltrans Office of Structural Material (OSM) Quality Assurance (QA) Inspector, D.Sukanthan was present during the time noted above for observations relative to the work being performed.

OBG # CROSSBEAM CB18

This QA inspector received ZPMC Non Destructive Testing (NDT) notification 09145 to perform Magnetic particle Testing (MT) of approximately 15% of the area previously tested and accepted by ZPMC Quality Control Personnel. This QA Inspector generated a Magnetic particle Test report for this date. The member is identified as Crossbeam CB18. The weld tested is identified as follows:

(CB3002K-003-027,028,031,032,043,044,035,036,041,042)

(CB3002K-003-161,162,163,164,165,166,167,168,169,170,171,172)

(CB3002K-003-173,174,175,176,177,178,179,180,181,182,183,184,185,186)

(CB3002K-003-187,188,189,190,191,192,193,194,195,196)

(CB3002K-003-231,232,233,234,235,236,237,238,239,240,241,242)

(CB3002K-003-243,244,245,246,247,248,249,250,251,252,253)

(CB3002K-003-254,255,256,257,258,259,260,261,262)

This QA Inspector randomly observed the following work in progress:

OBG # CROSSBEAM CB19

WELDING INSPECTION REPORT


(Continued Page 2 of 2)

This QA observed that ZPMC personnel perform Crossbeam CB19 fit-up to lift 14 East line and west line. No significant work was being performed on this crossbeam during the time QA was present.

OBG # SEGMENT 13AE 13BE

This QA observed ZPMC qualified welding personnel identified as 067184 perform Shielded Metal Arc Welding (SMAW) Process base metal repair on side panel. ZPMC Quality Control Personnel (QC) identified as Mr. Wang Liyang was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-345-SMAW-4G (4F)-FCM-Repair-1 and Critical Weld Repair Report B-CWR2969. See attached Photos.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.





Summary of Conversations:

As mention above

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 150-00422372, who represents the Office of Structural Materials for your project.

Inspected By:	Sukanthan, Dhanasingh	Quality Assurance Inspector
Reviewed By:	Hall,Steven	QA Reviewer